



System Name: XXX PWS ID# DE0000####

\_\_\_\_\_ Acceptable See Comments (if present) \_\_\_\_\_ Not Acceptable/Do Over/Resubmit

Y/N or N/A	Required Information Topic	Comments
	1. CCR delivered to customers AND ODW by July 1 <sup>st</sup> Certificate of delivery to ODW by July 10 <sup>th</sup>	

<b>Item 1: Required Information about the Water System</b>		
	2. Name of water system, phone number of a contact person who can provide more information and answer questions (Page 7 & 8 in <i>Preparing your Drinking Water CCR</i> )	
	3. Information on public participation opportunities (Page 8 in <i>Preparing your Drinking Water CCR</i> )	

<b>Item 2: Source(s) of Water</b>		
	4. Type of water source, general location of source and common name of source if applicable (e.g. name of river or aquifer) (Page 8 in <i>Preparing your Drinking Water CCR</i> )	
	5. Availability of source water assessment (Page 8 in <i>Preparing your Drinking Water CCR</i> )	
	6. Information on significant sources of contamination, if available. It is required to add a brief summary of the system's susceptibility to potential sources of contamination. (Page 8 & 9 in <i>Preparing your Drinking Water CCR</i> )	

<b>Item 3: Definitions</b>		
	7. Required: MCL & MCLG (Page 9 in <i>Preparing your Drinking Water CCR</i> )	
	8. Required if applicable: TT, AL, MRDL, MRDLG, (Page 9 in <i>Preparing your Drinking Water CCR</i> )	

<b>Item 4: Reported Levels of Detected Contaminants</b>		
	9. Table summarizing data on detected regulated and unregulated contaminants. Violations/exceedances must be highlighted. (Pages 10-17 in <i>Preparing your Drinking Water CCR</i> )	
	9a. Contaminant regulated by MCL or MRDL? Then: MCL or MRDL expressed as a number $\geq 1.0$ and MCLG or MRDLG same (Page 11, #1 & 5 in <i>Preparing your Drinking Water CCR</i> )	
	9b. Contaminant regulated by TT? Then: TT instead of MCL and N/A in place of MCLG when no MCLG is listed (Page 11, #2 & 5 in <i>Preparing your Drinking Water CCR</i> )	

Y/N or N/A	Required Information Topic	Comments
	9c. Contaminant regulated as AL? Then: AL = number $\geq$ 1.0 also, the MCLG expressed in same units as AL for copper, zero for lead (Page 11, #3 in <i>Preparing your Drinking Water CCR</i> )	
	9d. Lead and Copper: Use separate table for L&C. Report the round(s) of sampling in the target calendar year. Report 90 <sup>th</sup> percentile figure (if >0) <i>and</i> the number of sites that exceeded the action level. Non-detects may be reported for L&C only. (Page 13, #5e in <i>Preparing your Drinking Water CCR</i> )	
	9d.1 Lead or Copper 90 <sup>th</sup> percentile AL exceedance: include health effects statement and explanation of steps taken to correct the issue.	
	9e. Contaminant unregulated (UCMR)? Then: report <i>average level</i> and <i>range</i> . (Page 12, #4a in <i>Preparing your Drinking Water CCR</i> )	
	9f. <i>Detected</i> , regulated contaminants: report highest level detected and range alongside MCL & MCLG. (Page 12, #5a in <i>Preparing your Drinking Water CCR</i> )	
	9g. Total Coliforms: system collects less than 40 samples/month, then report highest <i>number</i> of positives; <b>OR</b> system collects more than 40/mo, then report highest <i>percentage</i> of positives in any one month. E.coli: report total number of positives in that year. (Page 13, #5f in <i>Preparing your Drinking Water CCR</i> )	
	9h. TTHM & HAA5 (Page 12c in <i>Preparing your Drinking Water CCR</i> )	
	9i. Turbidity: If turbidity is regulated as a TT, then include a statement explaining the reasons for measuring turbidity. (Page 13, #5d in <i>Preparing your Drinking Water CCR</i> )	
	9j. Gross alpha and combined radium: Do not report numbers less than 3.0 for gross alpha and 1.0 for combined radium.	
	9j. Beta Emitters (for Surface Water Systems only) Use 50 pCi/L in the MCL column rather than 4 mrem/yr. Exceedance? See p. 27 in EPA State Implementation	
	10. Known or likely source of each detected contaminant (Page 16, #5j in <i>Preparing your Drinking Water CCR</i> )	
	11. Health effects language and explanation for any violations or exceedances (length of violation, health effects, actions taken to address the violation/exceedance). This information must not be in the table but close to it. (Page 16, #5k in <i>Preparing your Drinking Water CCR</i> )	
	12. Required unspecific text for <i>detected</i> contaminants monitored less than once per year: <i>The state allows us to monitor for ...</i> (Page 11 in <i>Preparing your Drinking Water CCR</i> )	
	12a. Contaminant not detected? Do not include in the report. (all rules above specify <i>detected</i> contaminants) (Page 10, in <i>Preparing your Drinking Water CCR</i> )	
	12b. The calendar year of the report must be noted in report or table(s). Data from previous years must be noted in the table(s) with the year sampled. (Page 11, in <i>Preparing your Drinking Water CCR</i> )	

Y/N or N/A	Required Information Topic	Comments
---------------	----------------------------	----------

<b>Item 5: Information on Monitoring for <i>Cryptosporidium</i>, Radon and Other Contaminants</b>		
	13. Cryptosporidium present? Then: warning for vulnerable populations, non-specific language. (Page 17-19 in <i>Preparing your Drinking Water CCR</i> )	
	14. Radon detected? Then: explanation of radon and its presence, non-specific language. (Page 17-19 in <i>Preparing your DW CCR</i> )	
	15. Unregulated other contaminants present during voluntary monitoring? Then: explanation suggested, though not required. (Page 17-19 in <i>Preparing your Drinking Water CCR</i> )	

<b>Item 6: Compliance with Other Drinking Water Regulations</b>		
	16. Explanation of violations, potential health effects and steps taken to correct the violation (Page 19-22 in <i>Preparing your Drinking Water CCR</i> )	
	17. Special notices for GWR (Page 19-22 in <i>Preparing your Drinking Water CCR</i> )	

<b>Item 7: Variances and Exemptions</b>		
N/A	18. Explanation of variances/exemptions if applicable (Page 22 in <i>Preparing your Drinking Water CCR</i> )	Not Applicable in Delaware

<b>Item 8: Required Educational Information (specific language)</b>		
	19. Required specific: <i>Drinking water, including bottled water...</i> (Page 22 in <i>Preparing your Drinking Water CCR</i> )	
	20. Required specific: <i>Some people may be more vulnerable...</i> (Page 23 in <i>Preparing your Drinking Water CCR</i> )	
	21. Required non-specific: <i>The sources of drinking water (both tap water and bottled water) include rivers...</i> (Page 23 in <i>Preparing your Drinking Water CCR</i> )	
	22. Required specific: <i>If present, elevated levels of lead can cause serious health problems...</i> (Page 25 in <i>Preparing your Drinking Water CCR</i> )	
	23. Arsenic required specific if detected above 5 ppb but $\leq$ 10 ppb: <i>While your drinking water meets EPA's standard for arsenic...</i> (Page 24 in <i>Preparing your Drinking Water CCR</i> )	
	24. Nitrate required specific if detected above 5 ppm but $\leq$ 10 ppm: <i>Nitrate in drinking water at levels above 10 ppm is a health risk...</i> (Page 24 in <i>Preparing your Drinking Water CCR</i> )	

References as noted above:

*Preparing Your Drinking Water Consumer Confidence Report, Guidance for Water Suppliers*, EPA, April 2010. This reference book is available at the following web address:

<http://www.dhss.delaware.gov/dhss/dph/hsp/files/odwccrprep.pdf>

Y/N or N/A	Required Information Topic	Comments
---------------	----------------------------	----------

<b>State of Delaware Regulated Analytes (for systems with more than 500 service connections)</b>		
--	--	--

	<p>25. For detected unregulated analytes for which monitoring is required (except <i>Cryptosporidium</i>), the table(s) must include the average and range at which the contaminant was detected. [40 CFR141.153(d)(7)], 4.3.3.4.7 (Do not report non-detects. If the contaminant was sampled <i>less</i> than 5 years ago <i>and</i> detected <i>and</i> has not been sampled since, include that data in the table.)</p>	
	25a. Nickel: Delaware <b>Primary</b> MCL = 100 ppb	
	25b. MtBE: Delaware <b>Primary</b> MCL = 10.0 ppb	
	25c. Fluoride: Delaware <b>Primary</b> MCL = 2.0 ppm	
	<p>25d. Secondary Standards (SMCLs) Alkalinity = N/A Chloride = 250 mg/L (250 ppm) Hardness = N/A Iron = 0.30 mg/L (300 ppb) Manganese = 0.05 mg/L (50 ppb) pH = 6.5 – 8.5 Sodium = N/A Sulfate = 250 mg/L (250 ppm)</p>	

<b>Office of Drinking Water Recommended CCR Items</b>		
---	--	--

--	29. Included misleading or erroneous statements	
	30. Date of report	
--	31. Avoid stating that your drinking water <i>is</i> safe, or similar language as this may represent an unwarranted liability on your part.	

Comments: