



Consecutive Public Water System Self-assessment Tool





Consecutive System Water Quality Monitoring Requirements

The water quality monitoring requirements for consecutive community water systems and consecutive non-transient non-community water systems are identical except with one exception: radioactive contaminants. Only consecutive community water systems must monitor radioactive contaminants.

Monitoring requirements

- Total coliforms
- Chlorine residual
- Fluoride
- Lead and copper
- Disinfection byproducts
- Annual routine chemical